



# Compliance Statement

## Screened Category 7<sub>A</sub> ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable

**Eurolan Identification P/N EU 19D-F7A-23WT-R500**


**Category 7<sub>A</sub>, Individual Foil and Overall Braid Screened  
100 Ω, 4 Twisted Pairs, 23 AWG, Fire Retardant, LSFRHF, Copper Cable**

**Eurolan AB  
Johannesfredsvägen 12,  
SE-168 69 Bromma, Sweden**


***Compliance Statement No. 1181054A***

*This Screened ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 7<sub>A</sub> performance requirements of edition 1.0 of ISO/IEC Generic Cabling Standard 11801-1:2017, CENELEC Generic Cabling Standard EN 50173-1:2011, edition 2.1 of IEC Cable Standard 61156-5:2012, the Category 6<sub>A</sub> requirements of ANSI/TIA Generic Cabling Standard 568-C.2:2009 and the requirements of CENELEC Cable Standard EN 50288-9-1:2012. Fire Retardancy is verified according to IEC 60332-3-24 (Cat. C), IEC 61034-1, IEC 61034-2, incl. amendment 1 and IEC 60754-2. The cable has EMC Performance Rating 9. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.*

Hoersholm, 11<sup>th</sup> June 2018

  
Ole Lambertsen  
Test Responsible

Hoersholm, 11<sup>th</sup> June 2018

  
Jens Rytter Petersen  
General Manager