



- 1 THIS FOUNTAIN REQUIRES THE USE OF MODEL 6521FR FREEZE RESISTANT VALVE ASSEMBLY (SOLD SEPARATELY)
- 2 VALVE ASSEMBLY MUST BE INSTALLED IN A WARM AREA. PROVISIONS SHOULD BE MADE TO ALLOW ACCESS TO ACCESS PANEL

- 3. HOLD ROUGH-IN DIMENSIONS ± 1/4" (6.4mm).
- 4. * WHEN INSTALLING THIS UNIT LOCAL, STATE OR FEDERAL CODES SHOULD BE ADHERED TO. FOR INSTALLATION HEIGHTS OTHER THAN SHOWN, DIMENSIONS MARKED (*) MUST BE ADJUSTED ACCORDINGLY.

1455 KLEPPE LANE
SPARKS, NEVADA 89431
(775) 359-4712 FAX (775) 359-7424
E-MAIL: HAWES@HAWESCO.COM
WEBSITE: WWW.HAWESCO.COM

EDITION: 10/2010	DATE: 06/2010	MODEL(S): 1109FR/1109FRBP	DATE: 06/2010
ECN: 4177	DATE: 06/2010	INFO FAX DOC #: 2110937/2110937Z	DATE: 06/2010
APPROVED: 06/2010	DATE: 06/2010	INSTALLATION: EXHIBIT	DATE: 06/2010
REV: 1	DATE: 06/2010	REV: 1	DATE: 06/2010